



CERTIFICATE

No. Z1 04 10 39769 007

Holder of Certificate: **Idroenergy S.p.A.**

Via dell Artigianato, 2
57121 Livorno
ITALY

Certification Mark:



Product: **Gas Generators**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. See also notes overleaf.

Test report no.: 70046369

Valid until: 2009-10-31

Date, 2004-10-26

Page 1 of 2



**CERTIFICATE**

No. Z1 04 10 39769 007

Model(s): 3.7, 4.2, 5.0, 8.0, 11.0, 15.0, 19.0, 30.0, 60.0**Parameters:** 400 V (3~, PE)
13,6 - 350 kW, max. 244 A
Hydrogen: 2466 - 40000 l/h
Oxygen: 1233 - 20000 l/h
connected to line with transformers
1 - 4 electrolytic cells
modular concept, different sizes**Tested according to:** EN 60204-1:1997
EN 60079-10:1996
EN 294:1992
EN 954-1:1996
EN 349:1993
BGV B6:1997
BGV B7:1997**Production Facility(ies):** 39769